

SPECIFICATIONS, CONTRACT DOCUMENTS  
AND  
CONSTRUCTION DRAWINGS

CITY OF BUNKIE

REPLACEMENT HANGARS AT  
BUNKIE MUNICIPAL AIRPORT (2R6)

\*\*\*\*\*

ADDENDUM NO. 2

DATE ISSUED: THURSDAY, FEBRUARY 17, 2022 @ 9:00 A.M.

---

**BID DATE: WEDNESDAY, FEBRUARY 23, 2022 @ 4:30 P.M.**

---

PAN AMERICAN ENGINEERS, LLC  
1717 JACKSON STREET  
ALEXANDRIA, LOUISIANA 71301



---

Thomas C. David, Jr., P.E. 2-17-22

This addendum shall be part of the Contract Documents as provided in the Instructions to Bidders.

This addendum is issued for the purpose of modifying and/or clarifying the Specifications and/or Drawings and is to be construed as being as much a part of the original Contract Documents as though originally contained herein.

Acknowledge receipt of the addendum by inserting its number on Page 1 of the Bid Form. Failure to do so may subject the Bidder to disqualifications.

**SPECIFICATIONS AND CONTRACT DOCUMENTS**

**ITEM 1 SPECIFICATION SECTION 13400 PRE-ENGINEERED METAL BUILDING**

- Delete paragraph 1.7.B in its entirety.
- Replace paragraph 2.15 with the following:

Roof Vapor Barrier:

- A. Insulation to be 2-3/4" (R-8) fiber glass insulation laminated to a white Metalized Polypropylene Scrim Kraft facing secured to the underside of the roof with poultry netting. System R values under ASTM C1136.
- Delete paragraph 2.16 in its entirety.
- Delete paragraph 2.17 in its entirety.