



**ADDENDUM #1**

Wednesday, April 6, 2022

**JOB # BC2021-08-F  
MULTIPLE SCHOOL CAMPUS ADDITIONS  
OUTDOOR LEARNING SPACE/PAVILION  
EVANGELINE PARISH SCHOOL BOARD - OWNER**

\*\*\*\*\*

Each bidder shall note on his Bid Form receipt of Addendum #1; that his Bid is for the conditions set forth in this Addendum plus the complete Contract Documents.

SOLE RESPONSIBILITY FOR PROPER DELIVERY OF BID IN COMPLIANCE WITH THE OFFICIAL PROJECT ADVERTISEMENT IS THAT OF THE GENERAL CONTRACTOR'S.

**PROJECT MANUAL**

**03361 CONCRETE SEAL & DENSIFIER**

**Clarification – Application :** A 5 gallon container of this product should be enough to coat 1 full slab at an application rate of 750sf/gal. Apply this product at this rate. ( 1 5 gal. container per slab ) Each 5 gallon container is listed at approximately \$275.00.

**07210 THERMAL INSULATION :** Paragraph 2.02 METAL BUILDING HEAT BARRIER : Contractor may use foil one side, white one side product if the foil both side product cannot be obtained. Place foil side up. Product is to be laid perpendicular to the purlins over the poultry netting, prior to installing the metal panels. See other approved manufacturers at the end of this addendum.

**ARCHITECTURAL DRAWINGS**

- 1. **Sheet A211 – DETAILS 5 & 6**  
 General Contractor may use Standard Galvanized Unistrut in lieu of 8” 18 ga. cee channel as noted.  
 Contractor shall chemical bolt the Unistrut to the slab, and cross brace and bolt the Unistrut to the metal building frame for stability.

**OTHER ACCEPTABLE MANUFACTURERS:**

No Exceptions are taken to the following manufacturers and/or products for bidding purposes in addition to those specified. Substituting products other than those specified is based upon the best information now available. Should any modification be required to accommodate the substitute product, it is the responsibility of this supplier and/or subcontractor to include the cost of this modification in his quotation. It should be understood that any deviation from the products specified with respect to quality, details and performance in the opinion of the Architect is grounds for disapproval of this product subsequent to a contract award. Any manufacturer or product that is not listed here in the Specifications shall be deemed NOT ACCEPTABLE for this project. Verification of this is the responsibility of the General Contractor. The Architect, after the Contract Award, will strictly enforce this policy.

**ARCHITECTURAL:**

07210 THERMAL INSULATION : Radiant Heat Barrier : Radiant Guard – Reflex AIR PRO Single bubble 3/16” inch thick Reflective material : ecofoil – single bubble foil faced material.

07410 – METAL ROOF & WALL PANELS : Berridge Manufacturing Co. R-Panel 713-223-4971

13121 – PRE-ENGINEERED METAL BUILDINGS : Delta Consolidated, LLC 504-368-5453 : Ideal Steel 337-560-9667.

**THE FOLLOWING DOCUMENTS ARE ATTACHED TO THIS ADDENDUM AND ARE HEREBY MADE A PART OF THIS ADDENDUM #1 (ONE) :**

**SIGN IN SHEET FROM PRE-BID CONFERENCE**

**END OF ADDENDUM #1 (ONE)**




**MULTIPLE SCHOOL CAMPUSES OUTDOOR LEARNING SPACE/PAVILION  
EVANGELINE PARISH SCHOOL BOARD – OWNER  
JOB # BC2021-08.1**

**PRE-BID MEETING  
MARCH 31, 2022 at 3:00 p.m.**

*Attendance List*

<b>NAME</b>	<b>FIRM/COMPANY</b>	<b>PHONE NO.</b>	<b>EMAIL ADDRESS</b>
MIKE HOLT	Braddock Companies, LLC	318-704-4393	mike@braddockcompanies.com
Justin Floyd	Tudor, Inc.	318-445-3606	<a href="mailto:jfloyd@tudorcompanies.com">jfloyd@tudorcompanies.com</a>
Mitch Fontenot	Lavergne Construction, LLC	318-336-9726	<a href="mailto:captainfontenot@yahoo.com">captainfontenot@yahoo.com</a>
Phillip Lavergne	Lavergne Construction, LLC	337-692-4143	<a href="mailto:plavergneco@aol.com">plavergneco@aol.com</a>
Tony Bertrand	EPSB	337-277-6918	<a href="mailto:Anthony.bertrand@epsb.com">Anthony.bertrand@epsb.com</a>
Trent Descant	MD Descant, LLC	318-346-6657	<a href="mailto:trent@mddescantconstruction.com">trent@mddescantconstruction.com</a>
Isaac Deshotel	Pat Williams Construction	337-831-5513	<a href="mailto:Isaac.deshotel@patwilliamsconstruction.com">Isaac.deshotel@patwilliamsconstruction.com</a>
Austin Kerry	Bayou Rapides Corp	318-445-8050	<a href="mailto:Austin.kerry@brcontracting.com">Austin.kerry@brcontracting.com</a>
Michael J. Lombas	EPSB	337-580-2385	<a href="mailto:Mike.lombas@epsb.com">Mike.lombas@epsb.com</a>
Wayne Dardeau	EPSB Member	318-419-2134	<a href="mailto:waynedardeau@hotmail.com">waynedardeau@hotmail.com</a>
Bob Manuel	Bob's Electrical	337-831-2007	<a href="mailto:Bob.manuel.electrical@gmail.com">Bob.manuel.electrical@gmail.com</a>



**MULTIPLE SCHOOL CAMPUSES OUTDOOR LEARNING SPACE/PAVILLION**  
**EVANGELINE PARISH SCHOOL BOARD – OWNER**  
**JOB # BC2021-08.1**

**PRE-BID MEETING**  
**MARCH 31, 2022 at 3:00 p.m.**

Attendance List

NAME	FIRM/COMPANY	PHONE NO.	EMAIL ADDRESS
MIKE HOLT	BRADDOCK COMPANIES, LLC	318-704-4393	mike@braddockcompanies.com
Justin Floyd	Tudor, Inc.	318-445-3688	justin@tudorcompanies.com
Mitch Fontenot	Lavergne Construction LLC	337-336-9786	cap@fontenot@yahoo.com
Phillip Lavergne	Lavergne Construction LLC	337-692-4143	plavergne@tdaol.com
Tony Bertrand	EPDR	337-277-6918	anthony.bertrand@epdr.com
TRAKT Descanf	M.D. Descanf LLC	318-346-6657	frank.m.d@mdconstruction.com
Isaac Deshotel	Pat Williams Construction	337-631-5513	isaac.deshotel@patwilliamsconstruction.com
Austin Vermey	Bayou Properties Corporation	318-445-8050	austin.vermey@vaccontracting.com
Michael J. Combs	EPDR	337-580-2385	mike.lou.combs@epdr.com
Nancy Danbar	School Bd.	318-419-2134	nancydanbar@parish1.com
Bob Manuel	Bob's Electrical	337-831-2007	Bob.Manuel.Electrical@gmail.com