

**ADDENDUM NO. 1**

October 20, 2022

**PROJECT:** Dean Lee Research and Extension Center  
**PROJECT NO:** 21011  
**ISSUED BY:** Alliance Design Group, LLC



This Addendum is issued for the purpose of tracking revisions that were incorporated into the construction documents after the Fire Marshal review. The bid documents dated October, 2022 (drawings and specifications) include the revisions listed below.

**SPECIFICATIONS**

**GENERAL**

1. On all sheets, clarify that the project number is **19-607-21-01, F.19002405**; 01-107-05B-13, F.01004195 (Supplement); & **01-107-18-02, F.01004395 (Supplement)**

**BID FORM**

1. Revise the description of the Alternates as shown on the revised sheet.

**DRAWINGS**

**GENERAL**

1. On all sheets, clarify that the project number is **19-607-21-01, F.19002405**; 01-107-05B-13, F.01004195 (Supplement); & **01-107-18-02, F.01004395 (Supplement)**

**SHEET T000**

1. Revise Alternate descriptions as shown on revised sheet.

**SHEET A111**

1. Provide 1 hour rated walls and 1 hour rated ceiling around and in Storage 105 – see partition type B.

**SHEET A140**

1. Revise note 27 to read, “48” wide wood ADA bench with back.”

**SHEET A-142**

1. On elevation B3 and C1 have electric heaters – see mechanical

**SHEET A-142**

1. Add a fire extinguisher on a hook.

**SHEET A-310**

1. Provide 1 hour rated fire barrier UL U415 between Seed Storage 311 and the rest of the rooms as shown on revised sheet.

**SHEET A-330**

## **ADDENDUM NO. 1**

October 20, 2022

1. Revise Wall Section F3 to show 1 hour rated fire barrier as shown on revised sheet.

### **SHEET A-410**

1. Revise key note 6 to read “Install 2” layer of limestone under building”.
2. Add a fire extinguisher on a hook inside the building.

### **SHEET A-510**

1. Revise key note 6 to read “Install 2” layer of limestone under building”.
2. Revise length of building as shown on revised sheet.
3. Add a fire extinguisher on a hook inside the building.

### **SHEET A-520**

1. Revise length of building as shown on revised sheet.

### **SHEET A-530**

1. Revise length of building as shown on revised sheet.

### **SHEET A-601**

1. On doors 105, 124, 303B, 304B, and 307B; revise door rating to 45 Min.
2. Provide smoke gasketing at door 105.

### **SHEET A-602**

1. Remove window number 3K & 3L from Window Schedule.

### **SHEET A-702**

1. Revise gutter detail F4 as follows:
  - a. The existing gutter straps secure to the face of the wall not under the roof panel. Roof panel should not have to be removed to replace gutter.
  - b. Re-use existing gutter brackets on the bottom of the gutter.

**ALLIANCE DESIGN GROUP**  
1439 Centre Court, Ste 401  
ALEXANDRIA, LOUISIANA 71301  
(318) 445-3151